

West Virginia Department of Environmental Protection  
Division of Air Quality

*Earl Ray Tomblin*  
Governor

*Randy C. Huffman*  
Cabinet Secretary

# Permit to Operate



Pursuant to  
**Title V**  
of the Clean Air Act

*Issued to:*  
**Appalachian Power Company**  
**Ceredo Generating Station**  
**R30-09900081-2013**

---

*John A. Benedict*  
Director

*Issued: May 7, 2013 • Effective: May 20, 2013*  
*Expiration: May 7, 2018 • Renewal Application Due: November 7, 2017*

Permit Number: **R30-09900081-2013**  
Permittee: **Appalachian Power Company**  
Facility Name: **Ceredo Generating Station**  
Permittee Mailing Address: **1 Riverside Plaza, Columbus OH 43215-2373**

---

*This permit is issued in accordance with the West Virginia Air Pollution Control Act (West Virginia Code §§ 22-5-1 et seq.) and 45CSR30 — Requirements for Operating Permits. The permittee identified at the above-referenced facility is authorized to operate the stationary sources of air pollutants identified herein in accordance with all terms and conditions of this permit.*

---

Facility Location:	Ceredo, Wayne County, West Virginia
Facility Mailing Address:	1662 Walker Branch Road, Huntington, WV 25704
Telephone Number:	(304) 528-7190
Type of Business Entity:	Corporation
Facility Description:	Electric Generating Station
SIC Code:	4911
UTM Coordinates:	365.97 km Easting • 4247.45 km Northing • Zone 17

Permit Writer: Bobbie Scroggie

*Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.*

---

*Issuance of this Title V Operating Permit does not supersede or invalidate any existing permits under 45CSR13, 14 or 19, although all applicable requirements from such permits governing the facility's operation and compliance have been incorporated into the Title V Operating Permit.*

## Table of Contents

<b>1.0.</b>	<b>Emission Units and Active R13, R14, and R19 Permits.....</b>	<b>3</b>
<b>2.0.</b>	<b>General Conditions.....</b>	<b>4</b>
<b>3.0.</b>	<b>Facility-Wide Requirements and Permit Shield.....</b>	<b>12</b>

### Source-specific Requirements

<b>4.0.</b>	<b>Combustion Turbine Requirements .....</b>	<b>18</b>
<b>5.0.</b>	<b>Fuel Gas Heater Requirements .....</b>	<b>25</b>

**APPENDIX A** (CAIR Permit Application)

**APPENDIX B** (Permit R13-2382 Attachments)

## 1.0 Emission Units and Active R13, R14, and R19 Permits

### 1.1 Emission Units

Emission Unit ID	Emission Point ID	Emission Unit Description	Year Installed	Design Capacity	Control Device
1E	1S	Combustion Turbine, General Electric Model MS 7001 EA/PG7121(EA)	2000	1,215 mmBtu/hr	CO Catalyst 1C
2E	2S	Combustion Turbine, General Electric Model MS 7001 EA/PG7121(EA)	2000	1,215 mmBtu/hr	CO Catalyst 2C
3E	3S	Combustion Turbine, General Electric Model MS 7001 EA/PG7121(EA)	2000	1,215 mmBtu/hr	CO Catalyst 3C
4E	4S	Combustion Turbine, General Electric Model MS 7001 EA/PG7121(EA)	2000	1,215 mmBtu/hr	CO Catalyst 4C
5E	5S	Combustion Turbine, General Electric Model MS 7001 EA/PG7121(EA)	2000	1,215 mmBtu/hr	CO Catalyst 5C
6E	6S	Combustion Turbine, General Electric Model MS 7001 EA/PG7121(EA)	2000	1,215 mmBtu/hr	CO Catalyst 6C
7E	7S	Fuel Gas Heater, Heatec, Inc. Model H100-315	2000	14.2 mmBtu/hr	None

### 1.2 Active R13, R14, and R19 Permits

The underlying authority for any conditions from R13, R14, and/or R19 permits contained in this operating permit is cited using the original permit number (e.g. R13-1234). The current applicable version of such permit(s) is listed below.

Permit Number	Date of Issuance
R13-2382C	02/13/2009

## 2.0 General Conditions

### 2.1. Definitions

- 2.1.1. All references to the "West Virginia Air Pollution Control Act" or the "Air Pollution Control Act" mean those provisions contained in W.Va. Code §§ 22-5-1 to 22-5-18.
- 2.1.2. The "Clean Air Act" means those provisions contained in 42 U.S.C. §§ 7401 to 7671q, and regulations promulgated thereunder.
- 2.1.3. "Secretary" means the Secretary of the Department of Environmental Protection or such other person to whom the Secretary has delegated authority or duties pursuant to W.Va. Code §§ 22-1-6 or 22-1-8 (45CSR§30-2.12.). The Director of the Division of Air Quality is the Secretary's designated representative for the purposes of this permit.
- 2.1.4. Unless otherwise specified in a permit condition or underlying rule or regulation, all references to a "rolling yearly total" shall mean the sum of the monthly data, values or parameters being measured, monitored, or recorded, at any given time for the previous twelve (12) consecutive calendar months.

### 2.2. Acronyms

<b>CAAA</b>	Clean Air Act Amendments	<b>NSPS</b>	New Source Performance
<b>CBI</b>	Confidential Business Information		Standards
<b>CEM</b>	Continuous Emission Monitor	<b>PM</b>	Particulate Matter
<b>CES</b>	Certified Emission Statement	<b>PM<sub>10</sub></b>	Particulate Matter less than 10µm in diameter
<b>C.F.R. or CFR</b>	Code of Federal Regulations		
<b>CO</b>	Carbon Monoxide	<b>pph</b>	Pounds per Hour
<b>C.S.R. or CSR</b>	Codes of State Rules	<b>ppm</b>	Parts per Million
<b>DAQ</b>	Division of Air Quality	<b>PSD</b>	Prevention of Significant Deterioration
<b>DEP</b>	Department of Environmental Protection	<b>psi</b>	Pounds per Square Inch
<b>FOIA</b>	Freedom of Information Act	<b>SIC</b>	Standard Industrial Classification
<b>HAP</b>	Hazardous Air Pollutant		
<b>HON</b>	Hazardous Organic NESHAP	<b>SIP</b>	State Implementation Plan
<b>HP</b>	Horsepower	<b>SO<sub>2</sub></b>	Sulfur Dioxide
<b>lbs/hr or lb/hr</b>	Pounds per Hour	<b>TAP</b>	Toxic Air Pollutant
<b>LDAR</b>	Leak Detection and Repair	<b>TPY</b>	Tons per Year
<b>m</b>	Thousand	<b>TRS</b>	Total Reduced Sulfur
<b>MACT</b>	Maximum Achievable Control Technology	<b>TSP</b>	Total Suspended Particulate
<b>mm</b>	Million	<b>USEPA</b>	United States Environmental Protection Agency
<b>mmBtu/hr</b>	Million British Thermal Units per Hour	<b>UTM</b>	Universal Transverse Mercator
<b>mmft<sup>3</sup>/hr or mmcf/hr</b>	Million Cubic Feet Burned per Hour	<b>VEE</b>	Visual Emissions Evaluation
<b>NA or N/A</b>	Not Applicable		
<b>NAAQS</b>	National Ambient Air Quality Standards	<b>VOC</b>	Volatile Organic Compounds
<b>NESHAPS</b>	National Emissions Standards for Hazardous Air Pollutants		
<b>NO<sub>x</sub></b>	Nitrogen Oxides		

### **2.3. Permit Expiration and Renewal**

- 2.3.1. Permit duration. This permit is issued for a fixed term of five (5) years and shall expire on the date specified on the cover of this permit, except as provided in 45CSR§30-6.3.b. and 45CSR§30-6.3.c.  
[45CSR§30-5.1.b.]
- 2.3.2. A permit renewal application is timely if it is submitted at least six (6) months prior to the date of permit expiration.  
[45CSR§30-4.1.a.3.]
- 2.3.3. Permit expiration terminates the source's right to operate unless a timely and complete renewal application has been submitted consistent with 45CSR§30-6.2. and 45CSR§30-4.1.a.3.  
[45CSR§30-6.3.b.]
- 2.3.4. If the Secretary fails to take final action to deny or approve a timely and complete permit application before the end of the term of the previous permit, the permit shall not expire until the renewal permit has been issued or denied, and any permit shield granted for the permit shall continue in effect during that time.  
[45CSR§30-6.3.c.]

### **2.4. Permit Actions**

- 2.4.1. This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.  
[45CSR§30-5.1.f.3.]

### **2.5. Reopening for Cause**

- 2.5.1. This permit shall be reopened and revised under any of the following circumstances:
    - a. Additional applicable requirements under the Clean Air Act or the Secretary's legislative rules become applicable to a major source with a remaining permit term of three (3) or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to 45CSR§§30-6.6.a.1.A. or B.
    - b. Additional requirements (including excess emissions requirements) become applicable to an affected source under Title IV of the Clean Air Act (Acid Deposition Control) or other legislative rules of the Secretary. Upon approval by U.S. EPA, excess emissions offset plans shall be incorporated into the permit.
    - c. The Secretary or U.S. EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
    - d. The Secretary or U.S. EPA determines that the permit must be revised or revoked and reissued to assure compliance with the applicable requirements.
- [45CSR§30-6.6.a.]

## **2.6. Administrative Permit Amendments**

- 2.6.1. The permittee may request an administrative permit amendment as defined in and according to the procedures specified in 45CSR§30-6.4.  
[45CSR§30-6.4.]

## **2.7. Minor Permit Modifications**

- 2.7.1. The permittee may request a minor permit modification as defined in and according to the procedures specified in 45CSR§30-6.5.a.  
[45CSR§30-6.5.a.]

## **2.8. Significant Permit Modification**

- 2.8.1. The permittee may request a significant permit modification, in accordance with 45CSR§30-6.5.b., for permit modifications that do not qualify for minor permit modifications or as administrative amendments.  
[45CSR§30-6.5.b.]

## **2.9. Emissions Trading**

- 2.9.1. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in the permit and that are in accordance with all applicable requirements.  
[45CSR§30-5.1.h.]

## **2.10. Off-Permit Changes**

- 2.10.1. Except as provided below, a facility may make any change in its operations or emissions that is not addressed nor prohibited in its permit and which is not considered to be construction nor modification under any rule promulgated by the Secretary without obtaining an amendment or modification of its permit. Such changes shall be subject to the following requirements and restrictions:
- a. The change must meet all applicable requirements and may not violate any existing permit term or condition.
  - b. The permittee must provide a written notice of the change to the Secretary and to U.S. EPA within two (2) business days following the date of the change. Such written notice shall describe each such change, including the date, any change in emissions, pollutants emitted, and any applicable requirement that would apply as a result of the change.
  - c. The change shall not qualify for the permit shield.
  - d. The permittee shall keep records describing all changes made at the source that result in emissions of regulated air pollutants, but not otherwise regulated under the permit, and the emissions resulting from those changes.
  - e. No permittee may make any change subject to any requirement under Title IV of the Clean Air Act (Acid Deposition Control) pursuant to the provisions of 45CSR§30-5.9.

- f. No permittee may make any changes which would require preconstruction review under any provision of Title I of the Clean Air Act (including 45CSR14 and 45CSR19) pursuant to the provisions of 45CSR§30-5.9.

**[45CSR§30-5.9.]**

## **2.11. Operational Flexibility**

- 2.11.1. The permittee may make changes within the facility as provided by § 502(b)(10) of the Clean Air Act. Such operational flexibility shall be provided in the permit in conformance with the permit application and applicable requirements. No such changes shall be a modification under any rule or any provision of Title I of the Clean Air Act (including 45CSR14 and 45CSR19) promulgated by the Secretary in accordance with Title I of the Clean Air Act and the change shall not result in a level of emissions exceeding the emissions allowable under the permit.

**[45CSR§30-5.8]**

- 2.11.2. Before making a change under 45CSR§30-5.8., the permittee shall provide advance written notice to the Secretary and to U.S. EPA, describing the change to be made, the date on which the change will occur, any changes in emissions, and any permit terms and conditions that are affected. The permittee shall thereafter maintain a copy of the notice with the permit, and the Secretary shall place a copy with the permit in the public file. The written notice shall be provided to the Secretary and U.S. EPA at least seven (7) days prior to the date that the change is to be made, except that this period may be shortened or eliminated as necessary for a change that must be implemented more quickly to address unanticipated conditions posing a significant health, safety, or environmental hazard. If less than seven (7) days notice is provided because of a need to respond more quickly to such unanticipated conditions, the permittee shall provide notice to the Secretary and U.S. EPA as soon as possible after learning of the need to make the change.

**[45CSR§30-5.8.a.]**

- 2.11.3. The permit shield shall not apply to changes made under 45CSR§30-5.8., except those provided for in 45CSR§30-5.8.d. However, the protection of the permit shield will continue to apply to operations and emissions that are not affected by the change, provided that the permittee complies with the terms and conditions of the permit applicable to such operations and emissions. The permit shield may be reinstated for emissions and operations affected by the change:

- a. If subsequent changes cause the facility's operations and emissions to revert to those authorized in the permit and the permittee resumes compliance with the terms and conditions of the permit, or

- b. If the permittee obtains final approval of a significant modification to the permit to incorporate the change in the permit.

**[45CSR§30-5.8.c.]**

- 2.11.4. "Section 502(b)(10) changes" are changes that contravene an express permit term. Such changes do not include changes that would violate applicable requirements or contravene enforceable permit terms and conditions that are monitoring (including test methods), recordkeeping, reporting, or compliance certification requirements.

**[45CSR§30-2.39]**



## **2.12. Reasonably Anticipated Operating Scenarios**

2.12.1. The following are terms and conditions for reasonably anticipated operating scenarios identified in this permit.

- a. Contemporaneously with making a change from one operating scenario to another, the permittee shall record in a log at the permitted facility a record of the scenario under which it is operating and to document the change in reports submitted pursuant to the terms of this permit and 45CSR30.
- b. The permit shield shall extend to all terms and conditions under each such operating scenario; and
- c. The terms and conditions of each such alternative scenario shall meet all applicable requirements and the requirements of 45CSR30.

**[45CSR§30-5.1.i.]**

## **2.13. Duty to Comply**

2.13.1. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the West Virginia Code and the Clean Air Act and is grounds for enforcement action by the Secretary or USEPA; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

**[45CSR§30-5.1.f.1.]**

## **2.14. Inspection and Entry**

2.14.1. The permittee shall allow any authorized representative of the Secretary, upon the presentation of credentials and other documents as may be required by law, to perform the following:

- a. At all reasonable times (including all times in which the facility is in operation) enter upon the permittee's premises where a source is located or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times (including all times in which the facility is in operation) any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit;
- d. Sample or monitor at reasonable times substances or parameters to determine compliance with the permit or applicable requirements or ascertain the amounts and types of air pollutants discharged.

**[45CSR§30-5.3.b.]**

## **2.15. Schedule of Compliance**

2.15.1. For sources subject to a compliance schedule, certified progress reports shall be submitted consistent with the applicable schedule of compliance set forth in this permit and 45CSR§30-4.3.h., but at least every six (6) months, and no greater than once a month, and shall include the following:

- a. Dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
- b. An explanation of why any dates in the schedule of compliance were not or will not be met, and any preventative or corrective measure adopted.

**[45CSR§30-5.3.d.]**

## **2.16. Need to Halt or Reduce Activity not a Defense**

- 2.16.1. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. However, nothing in this paragraph shall be construed as precluding consideration of a need to halt or reduce activity as a mitigating factor in determining penalties for noncompliance if the health, safety, or environmental impacts of halting or reducing operations would be more serious than the impacts of continued operations.

**[45CSR§30-5.1.f.2.]**

## **2.17. Emergency**

- 2.17.1. An "emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

**[45CSR§30-5.7.a.]**

- 2.17.2. Effect of any emergency. An emergency constitutes an affirmative defense to an action brought for noncompliance with such technology-based emission limitations if the conditions of 45CSR§30-5.7.c. are met.

**[45CSR§30-5.7.b.]**

- 2.17.3. The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- a. An emergency occurred and that the permittee can identify the cause(s) of the emergency;
- b. The permitted facility was at the time being properly operated;
- c. During the period of the emergency the permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- d. Subject to the requirements of 45CSR§30-5.1.c.3.C.1, the permittee submitted notice of the emergency to the Secretary within one (1) working day of the time when emission limitations were exceeded due to the emergency and made a request for variance, and as applicable rules provide. This notice, report, and variance request fulfills the requirement of 45CSR§30-5.1.c.3.B. This notice must contain a detailed description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

**[45CSR§30-5.7.c.]**

- 2.17.4. In any enforcement proceeding, the permittee seeking to establish the occurrence of an emergency has the burden of proof.

[45CSR§30-5.7.d.]

- 2.17.5. This provision is in addition to any emergency or upset provision contained in any applicable requirement.

[45CSR§30-5.7.e.]

## **2.18. Federally-Enforceable Requirements**

- 2.18.1. All terms and conditions in this permit, including any provisions designed to limit a source's potential to emit and excepting those provisions that are specifically designated in the permit as "State-enforceable only", are enforceable by the Secretary, USEPA, and citizens under the Clean Air Act.

[45CSR§30-5.2.a.]

- 2.18.2. Those provisions specifically designated in the permit as "State-enforceable only" shall become "Federally-enforceable" requirements upon SIP approval by the USEPA.

## **2.19. Duty to Provide Information**

- 2.19.1. The permittee shall furnish to the Secretary within a reasonable time any information the Secretary may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the Secretary copies of records required to be kept by the permittee. For information claimed to be confidential, the permittee shall furnish such records to the Secretary along with a claim of confidentiality in accordance with 45CSR31. If confidential information is to be sent to USEPA, the permittee shall directly provide such information to USEPA along with a claim of confidentiality in accordance with 40 C.F.R. Part 2.

[45CSR§30-5.1.f.5.]

## **2.20. Duty to Supplement and Correct Information**

- 2.20.1. Upon becoming aware of a failure to submit any relevant facts or a submittal of incorrect information in any permit application, the permittee shall promptly submit to the Secretary such supplemental facts or corrected information.

[45CSR§30-4.2.]

## **2.21. Permit Shield**

- 2.21.1. Compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance provided that such applicable requirements are included and are specifically identified in this permit or the Secretary has determined that other requirements specifically identified are not applicable to the source and this permit includes such a determination or a concise summary thereof.

[45CSR§30-5.6.a.]

- 2.21.2. Nothing in this permit shall alter or affect the following:

- a. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance; or

- b. The applicable requirements of the Code of West Virginia and Title IV of the Clean Air Act (Acid Deposition Control), consistent with § 408 (a) of the Clean Air Act.
- c. The authority of the Administrator of U.S. EPA to require information under § 114 of the Clean Air Act or to issue emergency orders under § 303 of the Clean Air Act.

[45CSR§30-5.6.c.]

## **2.22. Credible Evidence**

- 2.22.1. Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the permittee including but not limited to any challenge to the credible evidence rule in the context of any future proceeding.

[45CSR§30-5.3.e.3.B. and 45CSR38]

## **2.23. Severability**

- 2.23.1. The provisions of this permit are severable. If any provision of this permit, or the application of any provision of this permit to any circumstance is held invalid by a court of competent jurisdiction, the remaining permit terms and conditions or their application to other circumstances shall remain in full force and effect.

[45CSR§30-5.1.e.]

## **2.24. Property Rights**

- 2.24.1. This permit does not convey any property rights of any sort or any exclusive privilege.

[45CSR§30-5.1.f.4]

## **2.25. Acid Deposition Control**

- 2.25.1. Emissions shall not exceed any allowances that the source lawfully holds under Title IV of the Clean Air Act (Acid Deposition Control) or rules of the Secretary promulgated thereunder.

- a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the acid deposition control program, provided that such increases do not require a permit revision under any other applicable requirement.
- b. No limit shall be placed on the number of allowances held by the source. The source may not, however, use allowances as a defense to noncompliance with any other applicable requirement.
- c. Any such allowance shall be accounted for according to the procedures established in rules promulgated under Title IV of the Clean Air Act.

[45CSR§30-5.1.d.]

- 2.25.2. Where applicable requirements of the Clean Air Act are more stringent than any applicable requirement of regulations promulgated under Title IV of the Clean Air Act (Acid Deposition Control), both provisions shall be incorporated into the permit and shall be enforceable by the Secretary and U. S. EPA.

[45CSR§30-5.1.a.2.]

### 3.0 Facility-Wide Requirements

#### 3.1. Limitations and Standards

- 3.1.1. **Open burning.** The open burning of refuse by any person is prohibited except as noted in 45CSR§6-3.1.  
[45CSR§6-3.1.]
- 3.1.2. **Open burning exemptions.** The exemptions listed in 45CSR§6-3.1 are subject to the following stipulation: Upon notification by the Secretary, no person shall cause or allow any form of open burning during existing or predicted periods of atmospheric stagnation. Notification shall be made by such means as the Secretary may deem necessary and feasible.  
[45CSR§6-3.2.]
- 3.1.3. **Asbestos.** The permittee is responsible for thoroughly inspecting the facility, or part of the facility, prior to commencement of demolition or renovation for the presence of asbestos and complying with 40 C.F.R. § 61.145, 40 C.F.R. § 61.148, and 40 C.F.R. § 61.150. The permittee, owner, or operator must notify the Secretary at least ten (10) working days prior to the commencement of any asbestos removal on the forms prescribed by the Secretary if the permittee is subject to the notification requirements of 40 C.F.R. § 61.145(b)(3)(i). The USEPA, the Division of Waste Management and the Bureau for Public Health - Environmental Health require a copy of this notice to be sent to them.  
[40 C.F.R. §61.145(b) and 45CSR34]
- 3.1.4. **Odor.** No person shall cause, suffer, allow or permit the discharge of air pollutants which cause or contribute to an objectionable odor at any location occupied by the public.  
[45CSR§4-3.1 State-Enforceable only.]
- 3.1.5. **Standby plan for reducing emissions.** When requested by the Secretary, the permittee shall prepare standby plans for reducing the emissions of air pollutants in accordance with the objectives set forth in Tables I, II, and III of 45CSR11.  
[45CSR§11-5.2]
- 3.1.6. **Emission inventory.** The permittee is responsible for submitting, on an annual basis, an emission inventory in accordance with the submittal requirements of the Division of Air Quality.  
[W.Va. Code § 22-5-4(a)(14)]
- 3.1.7. **Ozone-depleting substances.** For those facilities performing maintenance, service, repair or disposal of appliances, the permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 C.F.R. Part 82, Subpart F, except as provided for Motor Vehicle Air Conditioners (MVACs) in Subpart B:
- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the prohibitions and required practices pursuant to 40 C.F.R. §§ 82.154 and 82.156.
  - b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 C.F.R. § 82.158.
  - c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 C.F.R. § 82.161.
- [40 C.F.R. 82, Subpart F]

- 3.1.8. **Risk Management Plan.** Should this stationary source, as defined in 40 C.F.R. § 68.3, become subject to Part 68, then the owner or operator shall submit a risk management plan (RMP) by the date specified in 40 C.F.R. § 68.10 and shall certify compliance with the requirements of Part 68 as part of the annual compliance certification as required by 40 C.F.R. Part 70 or 71.  
[40 C.F.R. 68]
- 3.1.9. **CAIR NO<sub>x</sub> Annual Trading Program (Emission Units 1E - 6E).** The permittee shall comply with the standard requirements set forth in the attached CAIR Permit Application (see Appendix A) and the CAIR permit requirements set forth in 45CSR39 for each CAIR NO<sub>x</sub> Annual source. The complete CAIR Permit Application shall be the CAIR Permit portion of the Title V permit administered in accordance with 45CSR30.  
[45CSR§§39-6.1.b. and 20.1.]
- a. The CAIR Permit portion of this permit is deemed to incorporate automatically the definitions of terms under 45CSR§39-2 and, upon recordation by the Administrator under sections 51 through 57, or 60 through 62 of 45CSR39, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> Annual allowance to or from the compliance account of the CAIR NO<sub>x</sub> Annual source covered by the permit.  
[45CSR§39-23.2.]
- b. Except as provided in 45CSR§39-23.2, the Secretary will revise the CAIR Permit portion of this permit, as necessary, in accordance with the operating permit revision requirements set forth in 45CSR30.  
[45CSR§39-24.1.]
- 3.1.10. **CAIR NO<sub>x</sub> Ozone Season Trading Program (Emission Units 1E - 6E).** The permittee shall comply with the standard requirements set forth in the attached CAIR Permit Application (see Appendix A) and the CAIR permit requirements set forth in 45CSR40 for each CAIR NO<sub>x</sub> Ozone Season source. The complete CAIR Permit Application shall be the CAIR Permit portion of the Title V permit administered in accordance with 45CSR30.  
[45CSR§§40-6.1.b. and 20.1.]
- a. The CAIR Permit portion of this permit is deemed to incorporate automatically the definitions of terms under 45CSR§40-2 and, upon recordation by the Administrator under sections 51 through 57, or 60 through 62 of 45CSR40, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> Ozone Season allowance to or from the compliance account of the CAIR NO<sub>x</sub> Ozone Season source covered by the permit.  
[45CSR§40-23.2.]
- b. Except as provided in 45CSR§40-23.2, the Secretary will revise the CAIR Permit portion of this permit, as necessary, in accordance with the operating permit revision requirements set forth in 45CSR30.  
[45CSR§40-24.1.]
- 3.1.11. **CAIR SO<sub>2</sub> Trading Program (Emission Units 1E - 6E).** The permittee shall comply with the standard requirements set forth in the attached CAIR Permit Application (see Appendix A) and the CAIR permit requirements set forth in 45CSR41 for each CAIR SO<sub>2</sub> source. The complete CAIR Permit Application shall be the CAIR Permit portion of the Title V permit administered in accordance with 45CSR30.  
[45CSR§§41-6.1.b. and 20.1.]
- a. The CAIR Permit portion of this permit is deemed to incorporate automatically the definitions of terms under 45CSR§41-2 and, upon recordation by the Administrator under sections 51 through 57, or 60 through 62 of 45CSR41, every allocation, transfer, or deduction of a CAIR SO<sub>2</sub> allowance to or from the compliance account of the CAIR SO<sub>2</sub> source covered by the permit.  
[45CSR§41-23.2.]

- b. Except as provided in 45CSR§41-23.2, the Secretary will revise the CAIR Permit portion of this permit, as necessary, in accordance with the operating permit revision requirements set forth in 45CSR30.  
**[45CSR§41-24.1.]**

### **3.2. Monitoring Requirements**

- 3.2.1. None.

### **3.3. Testing Requirements**

- 3.3.1. **Stack testing.** As per provisions set forth in this permit or as otherwise required by the Secretary, in accordance with the West Virginia Code, underlying regulations, permits and orders, the permittee shall conduct test(s) to determine compliance with the emission limitations set forth in this permit and/or established or set forth in underlying documents. The Secretary, or his duly authorized representative, may at his option witness or conduct such test(s). Should the Secretary exercise his option to conduct such test(s), the operator shall provide all necessary sampling connections and sampling ports to be located in such manner as the Secretary may require, power for test equipment and the required safety equipment, such as scaffolding, railings and ladders, to comply with generally accepted good safety practices. Such tests shall be conducted in accordance with the methods and procedures set forth in this permit or as otherwise approved or specified by the Secretary in accordance with the following:
  - a. The Secretary may on a source-specific basis approve or specify additional testing or alternative testing to the test methods specified in the permit for demonstrating compliance with 40 C.F.R. Parts 60, 61, and 63, if applicable, in accordance with the Secretary's delegated authority and any established equivalency determination methods which are applicable.
  - b. The Secretary may on a source-specific basis approve or specify additional testing or alternative testing to the test methods specified in the permit for demonstrating compliance with applicable requirements which do not involve federal delegation. In specifying or approving such alternative testing to the test methods, the Secretary, to the extent possible, shall utilize the same equivalency criteria as would be used in approving such changes under Section 3.3.1.a. of this permit.
  - c. All periodic tests to determine mass emission limits from or air pollutant concentrations in discharge stacks and such other tests as specified in this permit shall be conducted in accordance with an approved test protocol. Unless previously approved, such protocols shall be submitted to the Secretary in writing at least thirty (30) days prior to any testing and shall contain the information set forth by the Secretary. In addition, the permittee shall notify the Secretary at least fifteen (15) days prior to any testing so the Secretary may have the opportunity to observe such tests. This notification shall include the actual date and time during which the test will be conducted and, if appropriate, verification that the tests will fully conform to a referenced protocol previously approved by the Secretary.
  - d. The permittee shall submit a report of the results of the stack test within 60 days of completion of the test. The test report shall provide the information necessary to document the objectives of the test and to determine whether proper procedures were used to accomplish these objectives. The report shall include the following: the certification described in paragraph 3.5.1; a statement of compliance status, also signed by a responsible official; and, a summary of conditions which form the basis for the compliance status evaluation. The summary of conditions shall include the following:
    - 1. The permit or rule evaluated, with the citation number and language.

2. The result of the test for each permit or rule condition.
3. A statement of compliance or non-compliance with each permit or rule condition.  
[WV Code §§ 22-5-4(a)(14-15) and 45CSR13]

### **3.4. Recordkeeping Requirements**

- 3.4.1. **Monitoring information.** The permittee shall keep records of monitoring information that include the following:
  - a. The date, place as defined in this permit and time of sampling or measurements;
  - b. The date(s) analyses were performed;
  - c. The company or entity that performed the analyses;
  - d. The analytical techniques or methods used;
  - e. The results of the analyses; and
  - f. The operating conditions existing at the time of sampling or measurement.  
[45CSR§30-5.1.c.2.A.]
- 3.4.2. **Retention of records.** The permittee shall retain records of all required monitoring data and support information for a period of at least five (5) years from the date of monitoring sample, measurement, report, application, or record creation date. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Where appropriate, records may be maintained in computerized form in lieu of the above records.  
[45CSR§30-5.1.c.2.B.]
- 3.4.3. **Odors.** For the purposes of 45CSR4, the permittee shall maintain a record of all odor complaints received, any investigation performed in response to such a complaint, and any responsive action(s) taken.  
[45CSR§30-5.1.c. State-Enforceable only.]

### **3.5. Reporting Requirements**

- 3.5.1. **Responsible official.** Any application form, report, or compliance certification required by this permit to be submitted to the DAQ and/or USEPA shall contain a certification by the responsible official that states that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.  
[45CSR§§30-4.4. and 5.1.c.3.D.]
- 3.5.2. A permittee may request confidential treatment for the submission of reporting required under 45CSR§30-5.1.c.3. pursuant to the limitations and procedures of W.Va. Code § 22-5-10 and 45CSR31.  
[45CSR§30-5.1.c.3.E.]
- 3.5.3. Except for the electronic submittal of the annual certification to the USEPA as required in 3.5.5 below, all notices, requests, demands, submissions and other communications required or permitted to be made to the



Secretary of DEP and/or USEPA shall be made in writing and shall be deemed to have been duly given when delivered by hand, mailed first class or by private carrier with postage prepaid to the address(es) set forth below or to such other person or address as the Secretary of the Department of Environmental Protection may designate:

**If to the DAQ:**

Director  
WVDEP  
Division of Air Quality  
601 57<sup>th</sup> Street SE  
Charleston, WV 25304  
Phone: 304/926-0475  
FAX: 304/926-0478

**If to the US EPA:**

Associate Director  
Office of Air Enforcement and Compliance  
Assistance (3AP20)  
U. S. Environmental Protection Agency  
Region III  
1650 Arch Street  
Philadelphia, PA 19103-2029

- 3.5.4. **Certified emissions statement.** The permittee shall submit a certified emissions statement and pay fees on an annual basis in accordance with the submittal requirements of the Division of Air Quality.  
[45CSR§30-8.]
- 3.5.5. **Compliance certification.** The permittee shall certify compliance with the conditions of this permit on the forms provided by the DAQ. In addition to the annual compliance certification, the permittee may be required to submit certifications more frequently under an applicable requirement of this permit. The annual certification shall be submitted to the DAQ and USEPA on or before March 15 of each year, and shall certify compliance for the period ending December 31. The annual certification to the USEPA shall be submitted in electronic format only. It shall be submitted by e-mail to the following address: [R3\\_APD\\_Permits@epa.gov](mailto:R3_APD_Permits@epa.gov). The permittee shall maintain a copy of the certification on site for five (5) years from submittal of the certification.  
[45CSR§30-5.3.e.]
- 3.5.6. **Semi-annual monitoring reports.** The permittee shall submit reports of any required monitoring on or before September 15 for the reporting period January 1 to June 30 and on or before March 15 for the reporting period July 1 to December 31. All instances of deviation from permit requirements must be clearly identified in such reports. All required reports must be certified by a responsible official consistent with 45CSR§30-4.4.  
[45CSR§30-5.1.c.3.A.]
- 3.5.7. **Emergencies.** For reporting emergency situations, refer to Section 2.17 of this permit.
- 3.5.8. **Deviations.**
- a. In addition to monitoring reports required by this permit, the permittee shall promptly submit supplemental reports and notices in accordance with the following:
1. Any deviation resulting from an emergency or upset condition, as defined in 45CSR§30-5.7., shall be reported by telephone or telefax within one (1) working day of the date on which the permittee becomes aware of the deviation, if the permittee desires to assert the affirmative defense in accordance with 45CSR§30-5.7. A written report of such deviation, which shall include the probable cause of such deviations, and any corrective actions or preventative measures taken, shall be submitted and certified by a responsible official within ten (10) days of the deviation.

2. Any deviation that poses an imminent and substantial danger to public health, safety, or the environment shall be reported to the Secretary immediately by telephone or telefax. A written report of such deviation, which shall include the probable cause of such deviation, and any corrective actions or preventative measures taken, shall be submitted by the responsible official within ten (10) days of the deviation.
3. Deviations for which more frequent reporting is required under this permit shall be reported on the more frequent basis.
4. All reports of deviations shall identify the probable cause of the deviation and any corrective actions or preventative measures taken.

**[45CSR§30-5.1.c.3.C.]**

- b. The permittee shall, in the reporting of deviations from permit requirements, including those attributable to upset conditions as defined in this permit, report the probable cause of such deviations and any corrective actions or preventive measures taken in accordance with any rules of the Secretary.

**[45CSR§30-5.1.c.3.B.]**

- 3.5.9. **New applicable requirements.** If any applicable requirement is promulgated during the term of this permit, the permittee will meet such requirements on a timely basis, or in accordance with a more detailed schedule if required by the applicable requirement.

**[45CSR§30-4.3.h.1.B.]**

### **3.6. Compliance Plan**

- 3.6.1. None.

### **3.7. Permit Shield**

- 3.7.1. The permittee is hereby granted a permit shield in accordance with 45CSR§30-5.6. The permit shield applies provided the permittee operates in accordance with the information contained within this permit.

#### **4.0 Combustion Turbine Requirements [Emission units 1E through 6E]**

##### **4.1. Limitations and Standards**

- 4.1.1. Sulfur content of the fuel combusted in the turbines shall not exceed 0.8 percent by weight.  
**[45CSR16, 40 C.F.R. § 60.333(b) and 45CSR13, R13-2382, B.7.]**
- 4.1.2. Nitrogen Oxides emissions from the turbine stacks shall not exceed 100 parts per million by volume on a dry basis at 15% oxygen.  
**[45CSR16, 40 C.F.R. § 60.332(a)(1) and 45CSR13, R13-2382, B.7.]**
- 4.1.3. At all times, including periods of startup, shutdown, and malfunction, the turbines and associated CO oxidation catalysts shall be, to the extent practicable, maintained and operated in a manner consistent with good air pollution practice for minimizing emissions.  
**[45CSR16, 40 C.F.R. § 60.11(d) and 45CSR13, R13-2382, B.7.]**
- 4.1.4. Emissions from the turbine stacks shall not exceed the following limits except during periods of startup and shutdown. Compliance with the annual emission limits shall be demonstrated using a 12 month rolling total.

<b>Pollutant</b>	<b>lbs/hr (each stack)</b>	<b>tons/year (total for all stacks)</b>
NO <sub>x</sub>	40	245.3
Sulfur Dioxide	5	5.0
PM-10	17	83.3
VOCs	4	13.6
CO	47	240.2
CO (without CO catalyst)	94	240.2
HAPs	1.0	7.4

*Compliance with this streamlined SO<sub>2</sub> limit assures compliance with 45CSR§10-4.1.*

**[45CSR13, R13-2382, A.1. and A.2.]**

- 4.1.5. Combustion turbines shall not combust more than  $12 \times 10^9$  scf/yr of fuel cumulatively on a rolling 12 month basis unless Continuous Emission Monitors (CEM's) for NO<sub>x</sub> are installed and operating.  
**[45CSR13, R13-2382, A.3.]**
- 4.1.6. CO oxidation catalysts, identified in permit application R13-2382A as 1C, 2C, 3C, 4C, 5C, and 6C, shall be installed, maintained, and operated so as to achieve a minimum 50.00% destruction efficiency in the control of Carbon Monoxide emissions from the turbines. The CO oxidation catalysts shall be utilized at all times except in the case of failure of the catalyst. In the event of failure of the catalyst, the permittee shall notify the Division of Air Quality within 24 hours. In no case shall the facility operate without the use of CO oxidation catalysts for more than 2,688 turbine-hours per year based on a rolling yearly total. Additionally, in no case shall the emission limitations set forth in 4.1.4. be exceeded except for hourly CO emissions which shall not exceed 94 lbs/hr during periods of catalyst failure.  
**[45CSR13, R13-2382, A.4.]**
- 4.1.7. The sulfur content of the gas being fired shall not exceed 1.32 grains/100 scf.  
**[45CSR13, R13-2382, A.5.]**
- 4.1.8. Combined hours of operation for the six turbines shall not exceed 15,150 hours per year unless Continuous Emission Monitors (CEM's) for NO<sub>x</sub> are installed and operating. Compliance with this limit shall be determined using a 12 month rolling average.  
**[45CSR13, R13-2382, A.6.]**

- 4.1.9. The gas turbines are Phase II Acid Rain affected units under 45CSR33, as defined by 40 C.F.R § 72.6, and as such are required to meet the requirements of 40 C.F.R. Parts 72, 73, 74, 75, 76, 77 and 78. These requirements include, but are not limited to:

1. Hold an Acid Rain permit;
2. Hold allowances, as of the allowance transfer deadline, in the unit's compliance sub-account of not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit;
3. Comply with the applicable Acid Rain emissions for sulfur dioxide;
4. Comply with the applicable Acid Rain emissions for nitrogen oxides;
5. Comply with the monitoring requirements of 40 C.F.R. Part 75 and section 407 of the Clean Air Act of 1990 and regulations implementing section 407 of the Act;
6. Submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 C.F.R. Part 72, Subpart I and 40 C.F.R. Part 75.

**[45CSR33 and 40 C.F.R. Parts 72, 73, 74, 75, 76, 77, 78]**

## **4.2. Monitoring Requirements**

- 4.2.1. The owners and operators of this facility shall comply with monitoring requirements as found in 40 C.F.R. 75. In lieu of continuous emission monitoring, the facility will demonstrate compliance with SO<sub>2</sub>, NO<sub>x</sub>, and CO emissions from the gas turbines following the procedures outlined in 40 C.F.R. 75.

**[45CSR33 and 40 C.F.R. § 72.9(b)(1)]**

- 4.2.2. In order to demonstrate compliance with the sulfur content limits of sections 4.1.1. and 4.1.7., along with the NO<sub>x</sub> emission limit of 4.1.2., the sulfur content and nitrogen content of the fuel being fired in the turbines shall be monitored per the following custom schedule approved by the Administrator:

1. Monitoring of fuel nitrogen content is not required while pipeline quality natural gas is the only fuel being fired in gas turbines.
2. Monitoring of fuel sulfur content:
  - a. Sulfur monitoring of the natural gas shall be performed once per ozone season using one of the approved ASTM methods or an approved alternative method. The reference methods are ASTM D1072-80, ASTM 3031-80, ASTM 3246-81, ASTM 4084-82 (referenced in §60.335(b)(2)) and the approved alternate method ASTM 6667-01.
  - b. Should any sulfur analysis required in section 4.2.2.2.a. indicate a noncompliance with 40 CFR §60.333, the owner/operator shall notify the EPA Regional Office Air Division and the WV DEP of such excess emissions and the custom schedule shall be re-examined by the EPA. Sulfur analysis shall be conducted weekly during the interim period while this custom schedule is being re-examined.
3. If there is a change in fuel supply, the owner or operator must notify the EPA and the WV DEP of such change for re-examination of this custom schedule. A substantial change in fuel quality shall be considered as a change in fuel supply. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.
4. Records of sample analysis and fuel supply pertinent to this custom schedule shall be retained for a period of five years, and be available to the Director or his duly authorized representative upon request.

Where appropriate, the owner or operator of a fuel burning units(s) may maintain such records in electronic form.

5. Because all six (6) turbines will share a common fuel supply, only one fuel gas sample need be collected and analyzed for all six turbines for compliance with Subpart GG.

**[45CSR16, 40 C.F.R. § 60.334(b), 45CSR13, R13-2382, B.7. , May 11, 2001 letter from EPA's Judith Katz "Re: Request for Custom Fuel Monitoring Schedule under Subpart GG of NSPS" and September 19, 2002 letter from EPA's Conniesue B. Oldham]**

- 4.2.3. The following parameters are to be monitored for purposes of demonstrating compliance with the Acid Rain Program requirements and the emission limits found in section 4.1.4.

- a. Inlet Guide Vane Position in degrees
- b. Exhaust Temperature in ° F
- c. Combustion Reference Temperature ° F
- d. Fuel Gas Split Set Point
- e.  $Q_v$  - Pipeline Natural Gas (PNG) Fuel Flow in scf/hr
- f. GCV - Fuel heat content (Btu/100scf)
- g. Online/Offline Signal
- h. Megawatt Load

**[45CSR33, 40 CFR 75, Appendix D, E, G and 45CSR§30-5.1.c.]**

- 4.2.4. **CAM monitoring requirement.** The permittee shall calibrate, maintain, and operate a temperature monitoring system with recorder consisting of 18 thermocouples to determine "calculated Turbine Exhaust Temperature Median Corrected by Average" at each Turbine Exhaust Diffuser. The thermocouples used in the monitoring system are to be accurate within  $\pm 1\%$  in degrees Fahrenheit per the thermocouple manufacturers published performance criteria. Sixteen of the eighteen thermocouples must be in operation at all times. The turbine will automatically shut down if three thermocouples are reading improperly.

**[45CSR§30-5.1.c. and 40 C.F.R. §§64.3(a), 64.3(b) and 64.6(c)(2)]**

- 4.2.5. **CAM monitoring requirement.** Compliance with the CO hourly emission limits set forth in Requirement 4.1.4. will be demonstrated if the "calculated Turbine Exhaust Temperature Median Corrected by Average" generated by the control system as per Requirement 4.2.4. is maintained at or above a minimum of 865 degree F during normal operations (not including periods of system startup, shutdown or maintenance). An excursion shall be defined as: if during normal operation, the 1-hour average of the "calculated Turbine Exhaust Temperature Median Corrected by Average" drops below 865°F. Excursions trigger an alarm, an inspection, evaluation and corrective action. The monitoring system shall collect the Turbine Exhaust Temperature, and record a 1-hour average of that temperature during the normal operating periods.

**[45CSR§30-12.7. and 40 C.F.R. §§64.3(a), 64.3(b) and 64.6(c)(2)]**

- 4.2.6. a. **Proper maintenance.** At all times, the owner or operator shall maintain the monitoring, including but not limited to, maintaining necessary parts for routine repairs of the monitoring equipment.
- b. **Continued operation.** Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the owner or operator shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. Data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities shall not be used for purposes of this part, including data averages and calculations, or fulfilling a minimum data availability requirement, if applicable. The owner or operator shall use all the data collected during all other periods in assessing the operation of the control device and associated control system. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

- c. **Response to excursions or exceedances.** Upon detecting an excursion or exceedance, the owner or operator shall restore operation of the pollutant-specific emissions unit (including the control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions. The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). Such actions may include initial inspection and evaluation, recording that operations returned to normal without operator action (such as through response by a computerized distribution control system), or any necessary follow-up actions to return operation to within the indicator range, designated condition, or below the applicable emission limitation or standard, as applicable.
- d. **Documentation of need for improved monitoring.** After approval of monitoring under this part, if the owner or operator identifies a failure to achieve compliance with an emission limitation or standard for which the approved monitoring did not provide an indication of an excursion or exceedance while providing valid data, or the results of compliance or performance testing document a need to modify the existing indicator ranges or designated conditions, the owner or operator shall promptly notify the permitting authority and, if necessary, submit a proposed modification to the part 70 or 71 permit to address the necessary monitoring changes. Such a modification may include, but is not limited to, reestablishing indicator ranges or designated conditions, modifying the frequency of conducting monitoring and collecting data, or the monitoring of additional parameters.

[40 C.F.R. §§64.7(b), 64.7(c), 64.7(d)(1) and 64.7(e)]

### 4.3. Testing Requirements

- 4.3.1. In lieu of CEMs, emission compliance tests of the Ceredo combustion turbines are due prior to the earlier of 3000 hours of operation of an individual unit or the 5-year anniversary and renewal of this operating permit. Stack testing will be conducted on each of three representative combustion turbines to determine NO<sub>x</sub> and CO emissions, and CO oxidation catalyst performance in accordance with the test protocol in Appendix A of the Acid Rain Program Monitoring Plan; the QA/QC information in section 6.6.2 must be recorded during testing. The results of the testing shall be used to demonstrate compliance with the NO<sub>x</sub> emissions limits of 4.1.2. and 4.1.4. as well as the minimum destruction efficiency limit for the CO oxidation catalysts in section 4.1.6.

[45CSR33, 40 CFR 75, and 45CSR13, R13-2382, B.15.]

### 4.4. Recordkeeping Requirements

- 4.4.1. Compliance with the mass emission limits of section 4.1.4. shall be demonstrated by performing the following calculations every month for the parameters monitored in 4.2.3. Each of the mass emissions will then be averaged on a monthly basis recorded and will then be used to create the monthly and 12-month rolling average emission reports.

**Heat Input Calculation**  $HI = (Q_v * GCV) / 10^6$

Where  $HI$  = heat input in mmBtu/hr  
 $Q_v$  = volumetric fuel flow in 100scf/hr  
 $GCV$  = Btu/100scf

**NO<sub>x</sub> Emission Rate**  $NO_x \text{ PPH} = NO_x * HI$

Where  $NO_x PPH = NO_x \text{ emissions in lbs/hr}$   
 $NO_x = NO_x \text{ emissions in lbs/mmBtu as calculated according to the requirements of 4.2.1.}$   
 $HI = \text{heat input in mmBtu/hr}$

During Startup: 21.6 minutes after flame-on is detected, add 14.6 lb to the total.

**SO<sub>2</sub> Emission Rate**  $M SO_2 = HI * ER SO_2$

Where  $M SO_2 = \text{mass emission for } SO_2 \text{ in lbs/hr}$   
 $ER SO_2 = \text{default emission rate for } SO_2 \text{ (0.0006 lb/mmBtu for natural gas)}$   
 $HI = \text{heat input in mmBtu/hr}$

**PM<sub>10</sub> Emission Rate** Use the following rules to track the PM<sub>10</sub> mass emissions

1. PM<sub>10</sub> emissions upstream of the CO catalyst will be 10 lbs/hr at all times.
2. The mass emission rates from SO<sub>2</sub> oxidation to H<sub>2</sub>SO<sub>4</sub> is calculated by multiplying the SO<sub>2</sub> emission by the ratio of the molecular weights: SO<sub>2</sub> (lbs/hr) \* (98/64).
3. PM<sub>10</sub> emissions are calculated as the sum of the upstream PM<sub>10</sub> emissions (1) and the resulting emissions from SO<sub>2</sub> oxidation to H<sub>2</sub>SO<sub>4</sub> (2).

**VOC Emission Rate** VOC emissions are tracked in one of the two following ways:

1. For compressor inlet temperatures greater than or equal to 59°F, multiply the heat input (mmBtu/hr) by 0.002 lb/mmBtu.
2. For compressor inlet temperatures less than 59°F, multiply the heat input (mmBtu/hr) by 0.003 lb/mmBtu.

**CO Emission Rate**

1. For compressor inlet temperatures greater than or equal to 59°F OR when the turbines reach base load, multiply the heat input (mmBtu/hr) by 0.027 lb/mmBtu.
2. For compressor inlet temperatures greater than or equal to 59°F OR when the turbines reach base load, multiply the heat input (mmBtu/hr) by 0.054 lb/mmBtu when operating without the CO catalyst.
3. For compressor inlet temperatures less than 59°F AND the turbines are at less than base load, multiply the heat input (mmBtu/hr) by 0.048 lb/mmBtu.
4. For compressor inlet temperatures less than 59°F AND the turbines are at less than base load, multiply the heat input (mmBtu/hr) by 0.096 lb/mmBtu when operating without the CO catalyst.
5. For each startup (defined as 21.6 minutes after flame-on is detected), add 25.5 lb to the total and add 51.0 lb to the total when operating without a catalyst.

**HAPs Emission Rate**

Multiply the heat input (HI) rate determined above by each of the emission factors (lbs/mmBtu) in the table below to track all of the HAP components.

1,3-Butadiene	4.3 x 10 <sup>-7</sup>
---------------	------------------------

Acetaldehyde	$7.8 \times 10^{-5}$
Acrolein	$7.7 \times 10^{-6}$
Benzene	$1.4 \times 10^{-4}$
Ethylbenzene	$2.4 \times 10^{-5}$
Formaldehyde	$2.9 \times 10^{-5}$
Napthalene	$1.4 \times 10^{-4}$
NDMA (N-nitrosodimethylamine)	$2.3 \times 10^{-7}$
NMOR (N-nitrosomorpholine)	$2.3 \times 10^{-7}$
PAH's (Polycyclic Aromatic Hydrocarbons)	$1.8 \times 10^{-4}$
Propylene Oxide	$2.8 \times 10^{-5}$
Toluene	$1.3 \times 10^{-4}$
Trimethylamine (TMA)	$1.7 \times 10^{-7}$
Xylene	$2.6 \times 10^{-5}$
Arsenic	$4.8 \times 10^{-8}$
Cadmium	$8.2 \times 10^{-7}$
Chromium-VI	$1.3 \times 10^{-6}$
Lead	$1.6 \times 10^{-5}$
Manganese	$1.6 \times 10^{-6}$
Mercury	$4.3 \times 10^{-7}$

**[45CSR§30-5.1.c.]**

- 4.4.2. For the purposes of determining compliance with the maximum fuel combustion limits set forth in 4.1.5., the applicant shall maintain certified daily records, utilizing the form identified as Attachment A (Appendix B of this permit). Such records shall be retained on-site by the permittee for at least five (5) years. Certified records shall be made available to the Director or his or her duly authorized representative upon request.

**[45CSR13, R13-2382, B.11]**

- 4.4.3. For the purposes of determining compliance with maximum hours of operation for the natural gas turbines set forth in 4.1.8., the applicant shall maintain certified daily records, utilizing the form identified as Attachment B (Appendix B of this permit). Such records shall be retained by the permittee for at least five (5) years. Certified records shall be made available to the Director or his or her duly authorized representative upon request.

**[45CSR13, R13-2382, B.12.]**

- 4.4.4. For the purposes of determining compliance with the maximum hours that the facility may operate the turbines without the use of the CO oxidation catalysts specified in 4.1.6., the permittee shall maintain certified daily records, utilizing the form identified as Attachment C (Appendix B of this permit). Such records shall be retained by the permittee for at least five (5) years. Certified records shall be made available to the Director or his or her duly authorized representative upon request.

**[45CSR13, R13-2382, B.16.]**



**4.4.5. General Recordkeeping Requirements for 40 C.F.R. Part 64 (CAM)**

1. The “calculated Turbine Exhaust Temperature Median Corrected by Average” determined per Requirement 4.2.5. shall be recorded hourly.
2. The permittee shall maintain records of monitoring data, monitor performance data, corrective actions taken, any written quality improvement plan required pursuant to 40 C.F.R. §64.8 and any activities undertaken to implement a quality improvement plan, and other supporting information required to be maintained under 40 C.F.R. Part 64 (such as data used to document the adequacy of monitoring, or records of monitoring maintenance or corrective actions).
3. Instead of paper records, the permittee may maintain records on alternative media, such as microfilm, computer files, magnetic tape disks, or microfiche, provided that the use of such alternative media allows for expeditious inspection and review, and does not conflict with other applicable recordkeeping requirements.

**[45CSR§30-5.1.c. and 40 C.F.R. §64.9(b)]**

**4.5. Reporting Requirements**

**4.5.1. General Reporting Requirements for 40 C.F.R. Part 64 (CAM)**

1. On and after the date specified in 40 C.F.R. §64.7(a) by which the permittee must use monitoring that meets the requirements of 40 C.F.R. Part 64, the permittee shall submit monitoring reports to the Director in accordance with permit condition 3.5.6.
2. A report for monitoring under 40 C.F.R. Part 64 shall include, at a minimum, the information required under permit condition 3.5.8. and the following information, as applicable:
  - i. Summary information on the number, duration and cause (including unknown cause, if applicable) of excursions or exceedances, as applicable, and the corrective actions taken;
  - ii. Summary information on the number, duration and cause (including unknown cause, if applicable) for monitor downtime incidents (other than downtime associated with zero and span or other daily calibration checks, if applicable); and
  - iii. A description of the actions taken to implement a QIP during the reporting period as specified in 40 C.F.R. §64.8. Upon completion of a QIP, the permittee shall include in the next summary report documentation that the implementation of the plan has been completed and reduced the likelihood of similar levels of excursions or exceedances occurring.

**[40 C.F.R. §64.9(a)]**

**4.6. Compliance Plan**

- 4.6.1. None.

## **5.0 Fuel Gas Heater Requirements [Emission Unit ID 7E]**

### **5.1. Limitations and Standards**

- 5.1.1. Emissions of smoke and/or particulate matter shall not exceed 10% opacity based on a six minute block average.  
**[45CSR§2-3.1. and 45CSR13, R13-2382, B.2.]**
- 5.1.2. Particulate matter emissions shall not exceed 1.28 lbs/hr.  
**[45CSR§2-4.1.b. and 45CSR13, R13-2382, B.2.]**
- 5.1.3. Sulfur dioxide emissions shall not exceed 45.50 lbs/hr.  
**[45CSR§10-3.3.f. and 45CSR13, R13-2382, B.3.]**
- 5.1.4. The fuel gas heater located on-site shall not combust more than  $49.8 \times 10^6$  scf/yr of fuel cumulatively on a rolling 12 month basis.  
**[45CSR13, R13-2382, A.7.]**

### **5.2. Monitoring Requirements**

- 5.2.1. None.

### **5.3. Testing Requirements**

- 5.3.1. None.

### **5.4. Recordkeeping Requirements**

- 5.4.1. Compliance with the particulate matter and sulfur dioxide emission limits of 5.1.2 and 5.1.3 shall be demonstrated by maintaining daily records of the operating schedule (operating hours per day) and the quantity of fuel consumed in the fuel gas heater on a daily basis. Sulfur content of the fuel will be monitored once a year in the form of fuel sulfur content certification from the fuel supplier. Such records are to be maintained on-site for a period of two years following the date of such record and made available to the Director or his duly authorized representative upon request. Where appropriate the owner or operator of a fuel burning units(s) may maintain such records in electronic form.

*Compliance with monitoring of fuel sulfur content for combustion turbines (Requirement 4.2.2.) may be used to demonstrate compliance with fuel sulfur content monitoring in this Requirement if the name of the supplier of the fuel, the potential sulfur emissions rate of the fuel in ng/J heat input, and the method used to determine the potential sulfur emissions rate of the fuel are included in the fuel sulfur content certification from the fuel supplier.*

**[45CSR16, 45CSR§2-8.3.c., 45CSR§2-8.3.d., 45CSR§2A-7.1.a. and 7.1.a.1., 40 C.F.R. § 60.48c(f), 40 C.F.R. § 60.48c(g) and 40 C.F.R. § 60.48c(i).]**

- 5.4.2. For the purposes of determining compliance with the maximum fuel combustion limits set forth in 5.1.4., the facility shall maintain certified daily records, utilizing the form identified as Attachment A (Appendix B of this permit). Such records shall be retained on-site by the permittee for at least five (5) years. Certified records shall be made available to the Director or his or her duly authorized representative upon request.  
**[45CSR13, R13-2382, B.11.]**

## **5.5. Reporting Requirements**

- 5.5.1. The permittee shall report to the Director any malfunction of a fuel burning unit (fuel gas heater) which results in any excess particulate matter emission rate or excess opacity.
- a. Excess opacity periods meeting the following conditions may be reported on a quarterly basis unless otherwise required by the Director:
    1. The excess opacity period does not exceed thirty (30) minutes within any 24-hour period; and
    2. Excess opacity does not exceed 40%.
  - b. The owner or operator shall report to the Director any malfunction resulting in excess particulate matter or excess opacity, not meeting the criteria set forth in 5.4.1.a, by telephone, telefax, or e-mail by the end of the next business day after becoming aware of such condition. The owner or operator shall file a certified written report concerning the malfunction with the Director within thirty (30) days providing the following information:
    1. A detailed explanation of the factors involved or causes of the malfunction;
    2. The date and time of during (with starting and ending times) of the period of excess emissions;
    3. An estimate of the mass of excess emissions discharged during the malfunction;
    4. The maximum opacity measured or observed during the malfunction;
    5. Immediate remedial actions taken at the time of the malfunction to correct or mitigate the effects of the malfunction; and
    6. A detailed explanation of the corrective measures or program that will be implemented to prevent a recurrence of the malfunction and a schedule for such implementation.
- [45CSR§2-9.3.]**
- 5.5.2. The reporting period for the reports required under 5.4.1. is each six-month period. All reports shall be submitted to the Administrator and shall be postmarked by the 30<sup>th</sup> day following the end of the reporting period.  
**[45CSR16, and 40 C.F.R. § 60.48c(j)]**

## **5.6. Compliance Plan**

- 5.6.1. None.

## **APPENDIX A**

CAIR Permit Application



# CAIR Permit Application

Page 1

For sources subject to the Clean Air Interstate Rule Trading Programs under 45CSR39, 45CSR40 and 45CSR41, the West Virginia Department of Environmental Protection, Division of Air Quality has prepared this CAIR Permit Application. Please refer to sections 21 and 22 of 45CSR39, 45CSR40 and 45CSR41, as applicable.

This submission is: ☒ New ☐ Revised

**STEP 1**  
Identify the source by plant name, and ORIS or facility code

Ceredo Generating Station	099-00081	55276
Plant Name	West Virginia ID Number	ORIS/Facility Code

**STEP 2**  
Enter the unit ID# for each CAIR unit and indicate to which CAIR programs each unit is subject (by placing an "X" in the column)

Unit ID#	NO <sub>x</sub> Annual	NO <sub>x</sub> Ozone Season	SO <sub>2</sub> Annual
01	X	X	X
02	X	X	X
03	X	X	X
04	X	X	X
05	X	X	X
06	X	X	X

**STEP 3**  
Read the standard requirements and the certification, enter the name of the CAIR designated representative, and sign and date

## Standard Requirements

### (a) Permit Requirements.

(1) The CAIR designated representative of each CAIR NO<sub>x</sub> Annual source, CAIR NO<sub>x</sub> Ozone Season source and CAIR SO<sub>2</sub> source (as applicable) required to have a Title V operating permit and each CAIR NO<sub>x</sub> Annual unit, CAIR NO<sub>x</sub> Ozone Season unit and CAIR SO<sub>2</sub> unit (as applicable) required to have a Title V operating permit at the source shall:

- Submit to the Secretary a complete CAIR permit application under 45CSR§39-22, 45CSR§40-22 and 45CSR§41-22 (as applicable) in accordance with the deadlines specified in 45CSR§39-21, 45CSR§40-21 and 45CSR§41-21 (as applicable); and
- Submit in a timely manner any supplemental information that the Secretary determines is necessary in order to review a CAIR permit application and issue or deny a CAIR permit.

(2) The owners and operators of each CAIR NO<sub>x</sub> Annual source, CAIR NO<sub>x</sub> Ozone Season source and CAIR SO<sub>2</sub> source (as applicable) required to have a Title V operating permit and each CAIR NO<sub>x</sub> Annual unit, CAIR NO<sub>x</sub> Ozone Season unit and CAIR SO<sub>2</sub> unit (as applicable) required to have a Title V operating permit at the source shall have a CAIR permit issued by the Secretary under sections 20 through 24 of 45CSR39, 45CSR40 and 45CSR41 (as applicable) for the source and operate the source and the unit in compliance with such CAIR permit.

(3) Except as provided in sections 80 through 88 of 45CSR39, 45CSR40 and 45CSR41, the owners and operators of a CAIR NO<sub>x</sub> Annual source, CAIR NO<sub>x</sub> Ozone Season source and CAIR SO<sub>2</sub> source (as applicable) that is not otherwise required to have a Title V operating permit and each CAIR NO<sub>x</sub> Annual unit, CAIR NO<sub>x</sub> Ozone Season unit and CAIR SO<sub>2</sub> unit (as applicable) that is not otherwise required to have a Title V operating permit are not required to submit a CAIR permit application and to have a CAIR permit, under sections 20 through 24 of 45CSR39, 45CSR40 and 45CSR41 (as applicable) for such CAIR NO<sub>x</sub> Annual source, CAIR NO<sub>x</sub> Ozone Season source and CAIR SO<sub>2</sub> source (as applicable) and such CAIR NO<sub>x</sub> Annual unit, CAIR NO<sub>x</sub> Ozone Season unit and CAIR SO<sub>2</sub> unit (as applicable).

STEP 3,  
continued

Ceredo Generating Station  
Plant Name

CAIR Permit Application  
Page 2

(b) Monitoring, reporting and recordkeeping requirements.

(1) The owners and operators and the CAIR designated representative, of each CAIR NO<sub>x</sub> Annual source, CAIR NO<sub>x</sub> Ozone Season source and CAIR SO<sub>2</sub> source (as applicable) and each CAIR NO<sub>x</sub> Annual unit, CAIR NO<sub>x</sub> Ozone Season unit and CAIR SO<sub>2</sub> unit (as applicable) at the source shall comply with the monitoring, reporting and recordkeeping requirements of sections 70 through 75 of 45CSR39, 45CSR40 and 45CSR41 (as applicable).

(2) The emissions measurements recorded and reported in accordance with sections 70 through 75 of 45CSR39, 45CSR40 and 45CSR41 (as applicable) shall be used to determine compliance by each CAIR NO<sub>x</sub> Annual source, CAIR NO<sub>x</sub> Ozone Season source and CAIR SO<sub>2</sub> source (as applicable) with the CAIR NO<sub>x</sub> Annual emissions limitation, CAIR NO<sub>x</sub> Ozone Season emissions limitation and CAIR SO<sub>2</sub> emissions limitation (as applicable) under 45CSR§39-6.3, 45CSR§40-6.3 and 45CSR§41-6.3 (as applicable).

(c) Nitrogen oxides annual emissions requirements.

(1) As of the allowance transfer deadline for the 2009 control period and each control period thereafter, the owners and operators of each CAIR NO<sub>x</sub> Annual source and each CAIR NO<sub>x</sub> Annual unit at the source shall hold, in the source's compliance account, CAIR NO<sub>x</sub> Annual allowances available for compliance deductions for the control period under 45CSR§39-54.1 in an amount not less than the tons of total nitrogen oxides emissions for the control period from all CAIR NO<sub>x</sub> Annual units at the source, as determined in accordance with sections 70 through 75 of 45CSR39.

(2) A CAIR NO<sub>x</sub> Annual unit shall be subject to the requirements under 45CSR§39-6.3.a for the control period starting on the later of January 1, 2009 or the deadline for meeting the unit's monitor certification requirements under subdivisions 70.2.a, 70.2.b, or 70.2.e of 45CSR39, and for each control period thereafter.

(3) A CAIR NO<sub>x</sub> Annual allowance shall not be deducted, for compliance with the requirements under 45CSR§39-6.3.a, for the control period in a calendar year before the year for which the CAIR NO<sub>x</sub> Annual allowance was allocated.

(4) CAIR NO<sub>x</sub> Annual allowances shall be held in, deducted from, or transferred into or among CAIR NO<sub>x</sub> Allowance Tracking System accounts in accordance with sections 50 through 62, and 80 through 88 of 45CSR39.

(5) A CAIR NO<sub>x</sub> Annual allowance is a limited authorization to emit one ton of nitrogen oxides in accordance with the CAIR NO<sub>x</sub> Annual Trading Program. No provision of the CAIR NO<sub>x</sub> Annual Trading Program, the CAIR permit application, the CAIR permit, or an exemption under 45CSR§39-5 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.

(6) A CAIR NO<sub>x</sub> Annual allowance does not constitute a property right.

(7) Upon recordation by the Administrator under sections 40 through 62, and 80 through 88 of 45CSR39, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> Annual allowance to or from a CAIR NO<sub>x</sub> Annual source's compliance account is incorporated automatically in any CAIR permit of the source.

(d) Nitrogen oxides ozone season emissions requirements.

(1) As of the allowance transfer deadline for the 2009 ozone season and each ozone season thereafter, the owners and operators of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO<sub>x</sub> Ozone Season allowances available for compliance deductions for the ozone season under 45CSR§40-54.1 in an amount not less than the tons of total nitrogen oxides emissions for the ozone season from all CAIR NO<sub>x</sub> Ozone Season units at the source, as determined in accordance with sections 70 through 75 of 45CSR40.

(2) A CAIR NO<sub>x</sub> Ozone Season unit shall be subject to the requirements under 45CSR§40-6.3.a for the ozone season starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under subdivisions 70.2.a, 70.2.b, 70.2.c or 70.2.g of 45CSR40 and for each ozone season thereafter.

(3) A CAIR NO<sub>x</sub> Ozone Season allowance shall not be deducted, for compliance with the requirements under 45CSR§40-6.3.a, for an ozone season in a calendar year before the year for which the CAIR NO<sub>x</sub> Ozone Season allowance was allocated.

(4) CAIR NO<sub>x</sub> Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO<sub>x</sub> Ozone Season Allowance Tracking System accounts in accordance with sections 50 through 62, and 80 through 88 of 45CSR40.

(5) A CAIR NO<sub>x</sub> Ozone Season allowance is a limited authorization to emit one ton of nitrogen oxides in accordance with the CAIR NO<sub>x</sub> Ozone Season Trading Program. No provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program, the CAIR permit application, the CAIR permit, or an exemption under 45CSR§40-5 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.

(6) A CAIR NO<sub>x</sub> Ozone Season allowance does not constitute a property right.

(7) Upon recordation by the Administrator under subdivision 43.3, sections 51 through 57, 60 through 62, and 80 through 88 of 45CSR40, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> Ozone Season allowance to or from a CAIR NO<sub>x</sub> Ozone Season source's compliance account is incorporated automatically in any CAIR permit of the source.

(e) Sulfur dioxide annual emission requirements.

(1) As of the allowance transfer deadline for the 2010 control period and each control period thereafter, the owners and operators of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall hold, in the source's compliance account, a tonnage equivalent of CAIR SO<sub>2</sub> allowances available for compliance deductions for the control period, as determined in accordance with subsections 54.1 and 54.2 of 45CSR§41 in an amount not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO<sub>2</sub> units at the source, as determined in accordance with sections 70 through 75 of 45CSR41.

(2) A CAIR SO<sub>2</sub> unit shall be subject to the requirements under 45CSR§41-6.3.a for the control period starting on the later of January 1, 2010 or the deadline for meeting the unit's monitor certification requirements under subdivisions 70.2.a, 70.2.b, or 70.2.e of 45CSR41 and for each control period thereafter.

(3) A CAIR SO<sub>2</sub> allowance shall not be deducted, for compliance with the requirements under 45CSR§41-6.3.a, for a control period in a calendar year before the year for which the CAIR SO<sub>2</sub> allowance was allocated.

(4) CAIR SO<sub>2</sub> allowances shall be held in, deducted from, or transferred into or among CAIR SO<sub>2</sub> Allowance Tracking System accounts in accordance with sections 51 through 62, and 80 through 88 of 45CSR41.

(5) A CAIR SO<sub>2</sub> allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO<sub>2</sub> Trading Program. No provision of the CAIR SO<sub>2</sub> Trading Program, the CAIR permit application, the CAIR permit, or an exemption under 45CSR§41-5 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.

(6) A CAIR SO<sub>2</sub> allowance does not constitute a property right.

(7) Upon recordation by the Administrator under sections 51 through 57, 60 through 62, and 80 through 88 of 45CSR41, every allocation, transfer, or deduction of a CAIR SO<sub>2</sub> allowance to or from a CAIR SO<sub>2</sub> source's compliance account is incorporated automatically in any CAIR permit of the source.

STEP 3,  
continued

(f) Excess emissions requirements.

(1) If a CAIR NO<sub>x</sub> Annual source emits nitrogen oxides during any control period in excess of the CAIR NO<sub>x</sub> Annual emissions limitation, then:

(i) The owners and operators of the source and each CAIR NO<sub>x</sub> Annual unit at the source shall surrender the CAIR NO<sub>x</sub> Annual allowances required for deduction under 45CSR§39-54.4.a and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or West Virginia Code §22-5-1 et seq; and

(ii) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 45CSR39, the Clean Air Act, and West Virginia Code §22-5-1 et seq.

(2) If a CAIR NO<sub>x</sub> Ozone Season source emits nitrogen oxides during any ozone season in excess of the CAIR NO<sub>x</sub> Ozone Season emissions limitation, then:

(i) The owners and operators of the source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall surrender the CAIR NO<sub>x</sub> Ozone Season allowances required for deduction under 45CSR§40-54.4.a and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or West Virginia Code §22-5-1 et seq; and

(ii) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 45CSR40, the Clean Air Act, and West Virginia Code §22-5-1 et seq.

(3) If a CAIR SO<sub>2</sub> source emits sulfur dioxide during any control period in excess of the CAIR SO<sub>2</sub> emissions limitation, then:

(i) The owners and operators of the source and each CAIR SO<sub>2</sub> unit at the source shall surrender the CAIR SO<sub>2</sub> allowances required for deduction under 45CSR§41-54.4.a and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or West Virginia Code §22-5-1 et seq; and

(ii) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 45CSR41, the Clean Air Act, and West Virginia Code §22-5-1 et seq.

(g) Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of a CAIR NO<sub>x</sub> Annual source, CAIR NO<sub>x</sub> Ozone Season source and CAIR SO<sub>2</sub> source (as applicable) and each CAIR NO<sub>x</sub> Annual unit, CAIR NO<sub>x</sub> Ozone Season unit and CAIR SO<sub>2</sub> unit (as applicable) at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Secretary or the Administrator.

(i) The certificate of representation under 45CSR§39-13, 45CSR§40-13 and 45CSR§41-13 (as applicable) for the CAIR designated representative for the source and each CAIR NO<sub>x</sub> Annual unit, CAIR NO<sub>x</sub> Ozone Season unit and CAIR SO<sub>2</sub> unit (as applicable) at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 45CSR§39-13, 45CSR§40-13 and 45CSR§41-13 (as applicable) changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with sections 70 through 75 of 45CSR39, 45CSR40 and 45CSR41 (as applicable), provided that to the extent that sections 70 through 75 of 45CSR39, 45CSR40 and 45CSR41 (as applicable) provides for a 3-year period for recordkeeping, the 3-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO<sub>x</sub> Annual Trading Program, CAIR NO<sub>x</sub> Ozone Season Trading Program and CAIR SO<sub>2</sub> Trading Program (as applicable).

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NO<sub>x</sub> Annual Trading Program, CAIR NO<sub>x</sub> Ozone Season Trading Program and CAIR SO<sub>2</sub> Trading Program (as applicable) or to demonstrate compliance with the requirements of the CAIR NO<sub>x</sub> Annual Trading Program, CAIR NO<sub>x</sub> Ozone Season Trading Program and CAIR SO<sub>2</sub> Trading Program (as applicable).

(2) The CAIR designated representative of a CAIR NO<sub>x</sub> Annual source, CAIR NO<sub>x</sub> Ozone Season source and CAIR SO<sub>2</sub> source (as applicable) and each CAIR NO<sub>x</sub> Annual unit, CAIR NO<sub>x</sub> Ozone Season unit and CAIR SO<sub>2</sub> unit (as applicable) at the source shall submit the reports required under the CAIR NO<sub>x</sub> Annual Trading Program, CAIR NO<sub>x</sub> Ozone Season Trading Program and CAIR SO<sub>2</sub> Trading Program (as applicable) including those under sections 70 through 75 of 45CSR39, 45CSR40 and 45CSR41 (as applicable).

(h) Liability.

(1) Each CAIR NO<sub>x</sub> Annual source, CAIR NO<sub>x</sub> Ozone Season source and CAIR SO<sub>2</sub> source (as applicable) and each NO<sub>x</sub> unit, CAIR NO<sub>x</sub> Ozone Season unit and CAIR SO<sub>2</sub> unit (as applicable) shall meet the requirements of the CAIR NO<sub>x</sub> Annual Trading Program, CAIR NO<sub>x</sub> Ozone Season Trading Program and CAIR SO<sub>2</sub> Trading Program (as applicable).

(2) Any provision of the CAIR NO<sub>x</sub> Annual Trading Program, CAIR NO<sub>x</sub> Ozone Season Trading Program or CAIR SO<sub>2</sub> Trading Program (as applicable) that applies to a CAIR NO<sub>x</sub> Annual source, CAIR NO<sub>x</sub> Ozone Season source or CAIR SO<sub>2</sub> source (as applicable) or the CAIR designated representative of a CAIR NO<sub>x</sub> Annual source, CAIR NO<sub>x</sub> Ozone Season source or CAIR SO<sub>2</sub> source (as applicable) shall also apply to the owners and operators of such source and of the CAIR NO<sub>x</sub> Annual units, CAIR NO<sub>x</sub> Ozone Season units or CAIR SO<sub>2</sub> units (as applicable) at the source.

(3) Any provision of the CAIR NO<sub>x</sub> Annual Trading Program, CAIR NO<sub>x</sub> Ozone Season Trading Program or CAIR SO<sub>2</sub> Trading Program (as applicable) that applies to a CAIR NO<sub>x</sub> Annual unit, CAIR SO<sub>2</sub> unit or CAIR NO<sub>x</sub> Ozone Season unit (as applicable) or the CAIR designated representative of a CAIR NO<sub>x</sub> Annual unit, CAIR NO<sub>x</sub> Ozone Season unit or CAIR SO<sub>2</sub> unit (as applicable) shall also apply to the owners and operators of such unit.

(i) Effect on Other Authorities.

No provision of the CAIR NO<sub>x</sub> Annual Trading Program, CAIR NO<sub>x</sub> Ozone Season Trading Program and CAIR SO<sub>2</sub> Trading Program (as applicable), a CAIR permit application, a CAIR permit, or an exemption under 45CSR§39-5, 45CSR§40-5, or 45CSR§41-5 (as applicable) shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO<sub>x</sub> Annual source, CAIR NO<sub>x</sub> Ozone Season source and CAIR SO<sub>2</sub> source (as applicable) or CAIR NO<sub>x</sub> Annual unit, CAIR NO<sub>x</sub> Ozone Season unit and CAIR SO<sub>2</sub> unit (as applicable) from compliance with any other provision of the applicable, approved State implementation plan, a federally enforceable permit, or the Clean Air Act.

Plant Name	Ceredo Generating Station
------------	---------------------------

STEP 3,  
continued

**Certification**

I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

CAIR Designated Representative	
John M. McManus	
Signature	Date
<i>John M. McManus</i>	5/25/07



## APPENDIX B - Permit R13-2382 Attachments

**Attachment A**  
**Natural Gas Usage**  
**Twelvepole Creek**  
 Plant ID No.: 099-00081  
 Permit No.: R13-2382  
 Month \_\_\_\_\_ Year \_\_\_\_\_

Day	Amount of Natural Gas used in fuel gas heater (scf)	Amount of Natural Gas Used in combustion turbines (scf)	Initials <sup>1</sup>
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
<b>Total</b>			

Note: <sup>1</sup>At the conclusion of filling in the required information each entry must be initialed by the individual entering the information

Rolling Yearly Total \_\_\_\_\_ scf (turbines)

Rolling Yearly Total \_\_\_\_\_ scf (heater)

\* The Certification of Data Accuracy statement on the reverse side of this form must be completed and signed by a responsible official within fifteen (15) days after the end of the calendar month. This record shall be maintained on site for a period of five (5) years for the date of certification. It shall be made available, upon request, to the Chief or his/her authorized representative.

**Attachment B**  
**Turbine & Fire Pump Engine Usage**  
**Twelvepole Creek**  
 Plant ID No.: 099-00081  
 Permit No.: R13-2382  
 Month \_\_\_\_\_ Year \_\_\_\_\_

Day	Number of Hours of Turbine Usage (all 6 turbines combined)	Number of Hours of Fire Pump Engine Usage	Initials <sup>1</sup>
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
<b>Total</b>			

Note: <sup>1</sup>At the conclusion of filling in the required information each entry must be initialed by the individual entering the information

Rolling Yearly Total \_\_\_\_\_ Hours (Turbines)  
 Rolling Yearly Total \_\_\_\_\_ Hours (Fire Pump Engine)

\* The Certification of Data Accuracy statement on the reverse side of this form must be completed and signed by a responsible official within fifteen (15) days after the end of the calendar month. This record shall be maintained on site for a period of five (5) years for the date of certification. It shall be made available, upon request, to the Chief or his/her authorized representative.

**Attachment C**  
**Turbine Usage Without CO Catalyst**  
**Twelvepole Creek**

Plant ID No.: 099-00081

Permit No.: R13-2382A

Month \_\_\_\_\_ Year \_\_\_\_\_

Day	Number of Hours Turbine #1 was used without a CO catalyst	Number of Hours Turbine #2 was used without a CO catalyst	Number of Hours Turbine #3 was used without a CO catalyst	Number of Hours Turbine #4 was used without a CO catalyst	Number of Hours Turbine #5 was used without a CO catalyst	Number of Hours Turbine #6 was used without a CO catalyst	Initials <sup>1</sup>
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
<b>Total</b>							

Note: <sup>1</sup>At the conclusion of filling in the required information each entry must be initialed by the individual entering the information

**Total Hours for the Month** \_\_\_\_\_ turbine-hours

**Rolling Yearly Total** \_\_\_\_\_ turbine-hours

\* The Certification of Data Accuracy statement on the reverse side of this form must be completed and signed by a responsible official within fifteen (15) days after the end of the calendar month. This record shall be maintained on site for a period of five (5) years for the date of certification. It shall be made available, upon request, to the Chief or his/her authorized representative.